



中国认可  
国际互认  
检测  
TESTING  
CNAS L0730



SOUTH CHINA NATIONAL CENTER OF METROLOGY  
GUANGDONG INSTITUTE OF METROLOGY

# TEST REPORT

No. XNZ202501232

Name of Sample: Single-Phase Energy Meter

Model / Type: PMC-220  
100-240 V 0,25-5(80) A 50/60 Hz

Sample Number: 3505169033, 3505169035, 3505169038, 3505169046

Applicant: CET Electric Technology Inc.


Manufacturer: CET Electric Technology Inc.

Test Type: Commission

Date Issued: 2025.12.06



(1) Basic Information

Name of Sample	Single-Phase Energy Meter	Trade Mark	
Model / Type	PMC-220 100-240 V 0,25-5(80) A 50/60 Hz	Class	Class. 1(Active)
Sample No.	3505169033, 3505169035, 3505169038, 3505169046	Sample quantity	4
Applicant	CET Electric Technology Inc.		
Address	Floor 33-35, Building #6, Shenzhen International Innovation Valley, Dashi First Road, Nanshan District, Shenzhen, Guangdong, P.R. China 518055		
Manufacturer	CET Electric Technology Inc.		
Test Site	Environment Lab of Dongguan Branch		
Test Conditions	Temperature: (25 ± 5)°C		Humidity: (50~70)%RH
Date Received	Aug. 15, 2025	Commission No.	WT20252290
Test Date	Aug. 15, 2025 to Oct. 30, 2025	Test Type	Commission
Test Item	See test result		
Test Standard	<ol style="list-style-type: none"> <li>IEC 62052-31(Edition 1.0):2015 Electricity metering equipment (AC) - General requirements, tests and test conditions - Part 31: Product safety requirements and tests</li> <li>AS 62052.31:2017+A1:2021 Electricity metering equipment (AC) - General requirements, tests and test conditions - Part 31: Product safety requirements and tests</li> </ol>		
Conclusion	PASS		
Remarks	—		



Tested by: 王海涛

Checked by: 徐煜彤

Approved by: 周晓辉