



HTW

Test Verification of Conformity

Certificate No.: CTE26010113

Date: 2026-01-16

In accordance with the following Applicable Directives:

2014/30/EU

Electromagnetic Compatibility

The equipment, as described herewith, was tested pursuant to applicable test procedure and complies with the requirements of:

EN IEC 61326-1: 2021 EN IEC 61326-2-3: 2021
EN 61000-4-2: 2009 EN IEC 61000-4-3: 2020
EN 61000-4-4: 2012 EN 61000-4-5: 2014+A1: 2017
EN 61000-4-6: 2014 EN 61000-4-8: 2010
EN IEC 61000-4-11: 2020 EN IEC 61000-6-4: 2019
EN IEC 61000-6-2: 2019 EN 55011: 2016+A1: 2017+A11: 2020+A2: 2021
EN IEC 61000-3-2: 2019+A1: 2021 EN 55032: 2015+AC: 2016+A11: 2020+A1: 2020
EN 61000-3-3: 2013+A1: 2019+A2: 2021

The test results are traceable to the international or national standards.

Applicant: **CET Electric Technology Inc.**
8/F, Westside, Building 201, Terra Industrial & Tradepark, Che Gong Miao, Shenzhen,
Guangdong, P.R. China 518040

Manufacturer: **CET Electric Technology Co., Ltd.**
8/F, Westside, Building 201, Terra Industrial & Tradepark, Che Gong Miao, Shenzhen,
Guangdong, P.R. China 518040

EUT Name: **Multi-Circuit Power Monitor**

Model number: **PMC-512-M4SCCT325BETHE**

Listed Model(s): **See Attachment Page**

Laboratory: **Shenzhen Huatongwei International Inspection Co., Ltd.**
Building 7, Baiwang Idea Factory, No.1051, Songbai Road, Yangguang Community, Xili Subdistrict, Nanshan District,
Shenzhen, Guangdong, China
Tel: 400-963-0755 E-mail: cs@szhtw.com.cn Website: [Http://www.szhtw.com.cn](http://www.szhtw.com.cn)

Note:

The certification is only valid for the equipment and configuration described, in conjunction with the test data detailed above.

For and on behalf of
Shenzhen Huatongwei International Inspection Co., Ltd.

Authorized by:

Tiger Jiang





Test Verification of Conformity

(Attachment Page)

Certificate No.: CTE26010113

Date: 2026-01-16

PMC-512-MXY325ZOP

“X” in the model name may represent 4 or 8 where

- 4 means 4x3-Phase SM (12x1- Φ or 4x3- Φ Sub-Meters)
- 8 means 8x3-Phase SM (24x1- Φ or 8x3- Φ Sub-Meters)

“Y” in the model name may represent SCCT or CT where

- SCCT means External Split-Core CT or Rogowski Coils
- CT means External Solid-Core CT

“Z” in the model name may represent N, A or B where

**Listed
Model(s):**

- N means 1xDO
- A means 12xDI + 1xIR + 4xNTC + 1xDO
- B means 4xDO + 4xIR + 4xNTC

“O” in the model name may represent N, 4G or ETH where

- N means None
- 4G means 4G communication
- ETH means 1xEthernet Port

“P” in the model name may represent C or E where

- C means Chinese
- E means English