



HTW

Test Verification of Conformity

Certificate No.: CTE26020006

Date: 2026-02-02

In accordance with the following Applicable Directives:

2014/30/EU

Electromagnetic Compatibility

The equipment, as described herewith, was tested pursuant to applicable test procedure and complies with the requirements of:

**EN IEC 61326-1: 2021 EN IEC 61326-2-3: 2021
EN 61000-4-2: 2009 EN IEC 61000-4-3:2020
EN 61000-4-4: 2012 EN 61000-4-5: 2014+A1: 2017
EN 61000-4-6: 2014 EN 61000-4-8: 2010
EN IEC 61000-4-11:2020 EN IEC 61000-6-4: 2019
EN IEC 61000-6-2:2019 EN 55011:2016+A1:2017+A11:2020+A2:2021
EN IEC 61000-3-2: 2019+A1: 2021 EN 55032: 2015+A11: 2020+A1: 2020
EN 61000-3-3: 2013+A1: 2019+A2: 2021**

The test results are traceable to the international or national standards.

Applicant: CET Electric Technology Inc.
8/F, Westside, Building 201, Terra Industrial & Tradepark, Che Gong Miao, Shenzhen,
Guangdong, P.R. China 518040

Manufacturer: CET Electric Technology Inc.
8/F, Westside, Building 201, Terra Industrial & Tradepark, Che Gong Miao, Shenzhen,
Guangdong, P.R. China 518040

EUT Name: Multi-Circuit Power Monitor

Model number: PMC-592-B5335100E

Listed Model(s): See Attachment Page

Laboratory: Shenzhen Huatongwei International Inspection Co., Ltd.

Building 7, Baiwang Idea Factory, No.1051, Songbai Road, Yangguang Community, Xili Subdistrict, Nanshan District,
Shenzhen, Guangdong, China

Tel: 400-963-0755

E-mail: cs@szhtw.com.cn

Website: [Http://www.szhtw.com.cn](http://www.szhtw.com.cn)

Note:

The certification is only valid for the equipment and configuration described, in conjunction with the test data detailed above.

For and on behalf of

Shenzhen Huatongwei International Inspection Co., Ltd.

Authorized by:

Tiger Jiang





Test Verification of Conformity

(Attachment Page)

Certificate No.: CTE26020006

Date: 2026-02-02

PMC-592-XY33ZOP

“X” in the model name may represent A or B where

- A means PMC-592 Base Unit with 2xDI
- B means PMC-592 Base Unit with 4xDI

“Y” in the model name may represent 5 or 1 where

- 5 means 5A Current Inputs for the 2 Mains Feeders
- 1 means 1A Current Inputs for the 2 Mains Feeders

Listed Model(s): “Z” in the model name may represent 5 or 6 where

- 5 means 50Hz
- 6 means 60Hz

“O” in the model name may represent 100 or 010 where

- 100 means 100A Fixed Core CT Strip or with CT Adapter Board and Branch SCCTs
- 010 means 10A Fixed Core CT Strip

“P” in the model name may represent C or E where

- C means Chinese
- E means English

CIC