



**HTW**

# Test Verification of Conformity

**Certificate No.: CTE26010207**

**Date: 2026-02-05**

In accordance with the following Applicable Directives:

**2014/30/EU**

## **Electromagnetic Compatibility**

The equipment, as described herewith, was tested pursuant to applicable test procedure and complies with the requirements of:

**EN IEC 61326-1: 2021 EN IEC 61326-2-3: 2021  
EN 61000-4-2: 2009 EN IEC 61000-4-3:2020  
EN 61000-4-4: 2012 EN 61000-4-5: 2014+A1: 2017  
EN 61000-4-6: 2014 EN 61000-4-8: 2010  
EN IEC 61000-4-11:2020 EN IEC 61000-6-4: 2019  
EN IEC 61000-6-2:2019 EN 55011:2016+A1:2017+A11:2020+A2:2021  
EN IEC 61000-3-2: 2019+A1: 2021 EN 55032: 2015+A11: 2020+A1: 2020  
EN 61000-3-3: 2013+A1: 2019+A2: 2021**

The test results are traceable to the international or national standards.

**Applicant:** CET Electric Technology Inc.  
8/F, Westside, Building 201, Terra Industrial & Tradepark, Che Gong Miao, Shenzhen,  
Guangdong, P.R. China 518040

**Manufacturer:** CET Electric Technology Inc.  
8/F, Westside, Building 201, Terra Industrial & Tradepark, Che Gong Miao, Shenzhen,  
Guangdong, P.R. China 518040

**EUT Name:** Multi-Circuit Power Monitor

**Model number:** PMC-592-A1325010E

**Listed Model(s):** See Attachment Page

**Laboratory:** Shenzhen Huatongwei International Inspection Co., Ltd.

Building 7, Baiwang Idea Factory, No.1051, Songbai Road, Yangguang Community, Xili Subdistrict, Nanshan District,  
Shenzhen, Guangdong, China

Tel: 400-963-0755

E-mail: cs@szhtw.com.cn

Website: [Http://www.szhtw.com.cn](http://www.szhtw.com.cn)

**Note:**

The certification is only valid for the equipment and configuration described, in conjunction with the test data detailed above.

For and on behalf of

Shenzhen Huatongwei International Inspection Co., Ltd.

**Authorized by:**

*Tiger Jiang*





# Test Verification of Conformity

(Attachment Page)

Certificate No.: CHTE26010207

Date: 2026-02-05

PMC-592-XY32ZOP

“X” in the model name may represent A or B where

- A means PMC-592 Base Unit with 2xDI
- B means PMC-592 Base Unit with 4xDI

“Y” in the model name may represent 5 or 1 where

- 5 means 5A Current Inputs for the 2 Mains Feeders
- 1 means 1A Current Inputs for the 2 Mains Feeders

“Z” in the model name may represent 5 or 6 where

Listed  
Model(s):

- 5 means 50Hz
- 6 means 60Hz

“O” in the model name may represent 100 or 010 where

- 100 means 100A Fixed Core CT Strip or with CT Adapter Board and Branch SCCTs
- 010 means 10A Fixed Core CT Strip

“P” in the model name may represent C or E where

- C means Chinese
- E means English

CIC