

Test Verification of Conformity

Certificate No.: CHTSE19050084R2

Date: 2026-01-08

In accordance with the following Applicable Directives:

2014/35/EU
Low Voltage Devices

The equipment, as described herewith, was tested pursuant to applicable test procedure and complies with the requirements of:

EN 61010-1: 2010+A1: 2019
EN IEC 61010-2-030:2021+A11:2021

The test results are traceable to the international or national standards.

Applicant: CET Electric Technology Inc.

8/F Westside Building 201 Terra Industrial & Tradepark Che Gong Miao, Shenzhen,
Guangdong, P.R. China 518040

Manufacturer: CET Electric Technology Inc.

8/F Westside Building 201 Terra Industrial & Tradepark Che Gong Miao, Shenzhen,
Guangdong, P.R. China 518040

EUT Name: DIN-Rail Advanced Power Quality Analyzer

Model number: iMeter D7-B5925ABAE

Listed Model(s): See Attachment Page

Laboratory: Shenzhen Huatongwei International Inspection Co., Ltd.

Huatongwei 101, No.006, Keji south 12th Road, High-tech zone community, Yuehai Street, Nanshan District,
Shenzhen, Guangdong, China

Tel: 400-963-0755

E-mail: cs@szhtw.com.cn

Website: [Http://www.szhtw.com.cn](http://www.szhtw.com.cn)



Note:

The certification is only valid for the equipment and configuration described, in conjunction with the test data detailed above.

The CE mark as shown beside can be used, under the responsibility of the manufacturer, after completion of an EC Directive of Conformity and compliance with all relevant EC Directive.

For and on behalf of

Shenzhen Huatongwei International Inspection Co., Ltd.

Authorized by:

Tiger Jiang





Test Verification of Conformity

(Attachment Page)

Certificate No.: CTSE19050084R2

Date: 2026-01-08

iMeter D7-XY92ZOPQR

“X” in the model name may represent A or B where

- A means IEC 61000-4-30 Ed. 3 Class A Compliance
- B means IEC 61000-4-30 Ed.3 Class A Compliance with 2-150kHz Measurements

“Y” in the model name may represent 1, 5, SCCT, SCCTA or SCCPA where

- 1 means 1A input
- 5 means 5A input
- SCCT means SCCT Option for use with For use with 100A/200A/400A/800A/1600A to 40mA SCCTs
- SCCTA means SCCT Option for use with For use with 5A/2mA SCCT
- SCCPA means SCCP Option for use with CT Clamps

“Z” in the model name may represent 5 or 6 where

- 5 means 50Hz
- 6 means 60Hz

Listed
Model(s):

“O” in the model name may represent A or B where

- A means 4xDI + 3xDO
- B means 4xDI + 3xSS Pulse Outputs

“P” in the model name may represent X, A or B where

- X means None
- A means 2xAI
- B means 1xlr + 1xRTD

“Q” in the model name may represent A or C where

- A means 2x10/100BaseT + 1xRS-485
- C means 2x10/100BaseT + 1xRS-485 + 4G (EU Band)

“R” in the model name may represent C or E where

- C means Chinese
- E means English