



中国认可
国际互认
检测
TESTING
CNAS L0730



SOUTH CHINA NATIONAL CENTER OF METROLOGY
GUANGDONG INSTITUTE OF METROLOGY

TEST REPORT

No. XNZ202602038

Name of Sample: Intelligent Multifunction Meter

Model / Type: PMC-S963
3×240/415 V 0,05-5(6) A 50 Hz

Sample Number: 3409142649

Applicant: CET Electric Technology Inc.

Manufacturer: CET Electric Technology Inc.

Test Type: Commission

Date Issued: 2026-03-17



(1) Basic Information

Name of Sample	Intelligent Multifunction Meter	Trade Mark	--
Model / Type	PMC-S963 3×240/415 V 0,05-5(6) A 50 Hz	Class	Class 0,5S (Active) Class 2 (Reactive)
Sample No.	3409142649	Sample quantity	1
Applicant	CET Electric Technology Inc.		
Address	8/F, Westside, Building 201, Terra Industrial & Tradepark, Che Gong Miao, Shenzhen, Guangdong, P.R. China 518040		
Manufacturer	CET Electric Technology Inc.		
Test Site	EMC Lab of Dongguan Branch		
Test Conditions	Temperature: (23±2) °C Humidity: (45~55) %RH		
Date Received	Mar. 9, 2026	Commission No.	WT20262098
Test Date	Mar. 9, 2026 to Mar. 11, 2026	Test Type	Commission
Test Item	See “Test Results Summary”		
Test Standard	<ol style="list-style-type: none"> IEC 62052-11 (Edition 2.0): 2020 Electricity metering equipment – General requirements, tests and test conditions – Part 11: Metering equipment IEC 62053-22 (Edition 2.0): 2020 Electricity metering equipment – Particular requirements – Part 22: Static meters for AC active energy (classes 0,1S, 0,2S and 0,5S) IEC 62053-23 (Edition 2.0): 2020 Electricity metering equipment – Particular requirements – Part 23: Static meters for reactive energy (classes 2 and 3) 		
Conclusion	PASS		
Remarks	Other Meter Specification: Transformer-operated, 3 phases 4 wires, 5000 imp/kWh and 5000 imp/kvarh, positive direction and negative direction.		



Tested by: 李泳璇

Checked by: *Liiker* Approved by: 周塔佛