



**HTW**

# Test Verification of Conformity

**Certificate No.: CTE25090065-1**

**Date: 2026-04-16**

In accordance with the following Applicable Directives:

## The Electrical Equipment (Safety) Regulations 2016

The equipment, as described herewith, was tested pursuant to applicable test procedure and complies with the requirements of:

**BS EN 61010-1: 2010+A: 2019**  
**BS EN IEC 61010-2-030: 2021+A11: 2021**

The test results are traceable to the international or national standards.

**Applicant:** CET Electric Technology Inc.  
Floor 33-35, Building #6, Shenzhen International Innovation Valley, Dashi First Road,  
Nanshan District, Shenzhen, Guangdong, P.R. China 518055

**Manufacturer:** CET Electric Technology Inc.  
2,3,4,5 floors of Building 4, Beishan Industrial Area, Beishan Street, Yan Tian,  
Shenzhen, Guangdong, P.R.China

**EUT Name:** Three-Phase Energy Meter

**Model number:** PMC-340-A6LB35CAME

**Listed Model(s):** See Attachment Page

**Laboratory:** Shenzhen Huatongwei International Inspection Co., Ltd.  
Building 7, Baiwang Idea Factory, No.1051, Songbai Road, Yangguang Community, Xili Subdistrict, Nanshan District,  
Shenzhen, Guangdong, China  
Tel: 400-963-0755 E-mail: cs@szhtw.com.cn Website: Http://www.szhtw.com.cn



**Note:**

The certification is only valid for the equipment and configuration described, in conjunction with the test data detailed above.  
The UKCA mark as shown beside can be used, under the responsibility of the manufacturer, after completion of an UK Regulation of Conformity and compliance with all relevant UK Regulation.

For and on behalf of  
Shenzhen Huatongwei International Inspection Co., Ltd.

**Authorized by:**

*Tiger Jiang*





# Test Verification of Conformity

(Attachment Page)

Certificate No.: CTE25090065-1

Date: 2026-04-16

PMC-340-A6LX35YAMZ

“X” in the model name may represent A or B where

- A means 10A (100A), Direct Connected Input
- B means 1A (10A), CT Input

“Y” in the model name may represent A,B or C where

**Listed  
Model(s):**

- A means 1xSS Pulse Output
- B means 1xDI
- C means 1xSS Pulse Output + 1xDI

“Z” in the model name may represent C or E where

- C means Chinese
- E means English



CIC