

Test Verification of Conformity

Certificate No.: CTM26065322

Date: 2026-06-18

In accordance with the following Applicable Directives:

The Electrical Equipment (Safety) Regulations 2016

The equipment, as described herewith, was tested pursuant to applicable test procedure and complies with the requirements of:

BS EN 61010-1: 2010+A: 2019
BS EN IEC 61010-2-030: 2021+A11: 2021

The test results are traceable to the international or national standards.

Applicant: **CET Electric Technology Inc.**
8/F, Westside, Building 201, Terra Industrial & Tradepark, Che Gong Miao, Shenzhen,
Guangdong, P.R. China 518040

Manufacturer: **CET Electric Technology Inc.**
8/F, Westside, Building 201, Terra Industrial & Tradepark, Che Gong Miao, Shenzhen,
Guangdong, P.R. China 518040

EUT Name: **Advanced Modular Power Quality Analyzer**

Model number: **iMeter 5-A5925AAE**

Listed Model(s): **See Attachment Page**

Laboratory: **Shenzhen Huatongwei International Inspection Co., Ltd.**

Building 7, Baiwang Idea Factory, No.1051, Songbai Road, Yangguang Community, Xili Subdistrict, Nanshan District,
Shenzhen, Guangdong, China

Tel: 400-963-0755

E-mail: cs@szhtw.com.cn

Website: [Http://www.szhtw.com.cn](http://www.szhtw.com.cn)

**UK
CA**

Note:

The certification is only valid for the equipment and configuration described, in conjunction with the test data detailed above.

The UKCA mark as shown beside can be used, under the responsibility of the manufacturer, after completion of an UK Regulation of Conformity and compliance with all relevant UK Regulation.

For and on behalf of

Shenzhen Huatongwei International Inspection Co., Ltd.

Authorized by: *Tiger Jiang*





Test Verification of Conformity

(Attachment Page)

Certificate No.: CTM26065322

Date: 2026-06-18

iMeter 5 - XY9O5PAQ

“X” in the model name may represent B, P, S or A where

- B means Basic Model
- P means Classic Model (PQA)
- S means Class S Model (PQI-S), IEC 61000-4-30 Ed. 3 Class S Compliance
- A means Class A Model (PQI-A), IEC 61000-4-30 Ed. 3 Class A Compliance

“Y” in the model name may represent 1, 5, SCCT, or SCCPA where

- 1 means 1A input
- 5 means 5A input
- SCCPA means SCCP Option for use with CT Clamps with max. 500mV output
- SCCT means SCCT Option for use with SCCT with max. 333mV output

**Listed
Model(s):**

“O” in the model name may represent 2 or 3 where

- 2 means power supply input: 95-277VAC/DC $\pm 10\%$, 47-440Hz.
- 3 means power supply input: 20-60VDC

“P” in the model name may represent A or B where

- A means 4xDI + 2xDO (Form A Mechanical Relay)
- B means 4xDI + 2xSS Pulse Output

“Q” in the model name may represent C or E where

- C means Chinese
- E means English