

Test Verification of Conformity

Certificate No.: CTM26065325

Date: 2026-06-18

In accordance with the following Applicable Directives:

The Electrical Equipment (Safety) Regulations 2016

The equipment, as described herewith, was tested pursuant to applicable test procedure and complies with the requirements of:

BS EN 61010-1: 2010+A: 2019
BS EN IEC 61010-2-030: 2021+A11: 2021

The test results are traceable to the international or national standards.

Applicant: **CET Electric Technology Inc.**
8/F, Westside, Building 201, Terra Industrial & Tradepark, Che Gong Miao, Shenzhen,
Guangdong, P.R. China 518040

Manufacturer: **CET Electric Technology Inc.**
8/F, Westside, Building 201, Terra Industrial & Tradepark, Che Gong Miao, Shenzhen,
Guangdong, P.R. China 518040

EUT Name: **Advanced Power Quality Analyzer**

Model number: **iMeter 7A-A5925AAE**

Listed Model(s): **See Attachment Page**

Laboratory: **Shenzhen Huatongwei International Inspection Co., Ltd.**

Building 7, Baiwang Idea Factory, No.1051, Songbai Road, Yangguang Community, Xili Subdistrict, Nanshan District,
Shenzhen, Guangdong, China

Tel: 400-963-0755

E-mail: cs@szhtw.com.cn

Website: [Http://www.szhtw.com.cn](http://www.szhtw.com.cn)

**UK
CA**

Note:

The certification is only valid for the equipment and configuration described, in conjunction with the test data detailed above.

The UKCA mark as shown beside can be used, under the responsibility of the manufacturer, after completion of an UK Regulation of Conformity and compliance with all relevant UK Regulation.

For and on behalf of

Shenzhen Huatongwei International Inspection Co., Ltd.

Authorized by:

Tiger Jiang





Test Verification of Conformity

(Attachment Page)

Certificate No.: CTM26065325

Date: 2026-06-18

iMeter 7A-OP9QRSAT

“O” in the model name may represent A or B where

- A means IEC 61000-4-30 Ed. 3 Class A Compliance
- B means IEC 61000-4-30 Ed. 3 Class A Compliance with 2kHz-150kHz C. E. Measurements
- C means Model A + New UI for Display
- D means Model B + New UI for Display

“P” in the model name may represent 1, 5, SCCT, SCCTA or SCCPA where

- 1 means 1A input
- 5 means 5A input
- SCCT means SCCT Option for use with 100A/200A/400A/800A/1600A to 40mA SCCTs
- SCCTA means SCCT Option for use with 5A/2mA SCCTs
- SCCPA means SCCP Option for use with CT Clamps with max. 500mV output

Listed

Model(s):

“Q” in the model name may represent 2 or 3 where

- 2 means power supply input: 95-250VAC/DC $\pm 10\%$, 47-440Hz.
- 3 means power supply input: 20-60VDC

“R” in the model name may represent 5 or 6 where

- 5 means 50Hz
- 6 means 60Hz

“S” in the model name may represent A, B, C or D where

- A means 4xDI + 3xDO
- B means 4xDI + 1xDO + 2xSS Pulse Outputs
- C means 8xDI + 5xDO + 2xAI
- D means 8xDI + 5xDO + 2xRTD Inputs

“T” in the model name may represent C or E where

- C means Chinese
- E means English